



WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3448406-118-2025

MDE OFFICIAL CONTACTED: CHRISTY WAGNER

DATA CALLED IN BY: BRANDON T MCCREA

DATE: 03/21/2025 AT 02:25PM

WORK ORDER(S): 3448406 3448442

EST DATE AND TIME SSO BEGAN: 03/21/2025 01:00PM DURATION: 0.83 HRS

DATE AND TIME SSO ENDED: 03/21/2025 01:50PM

SOURCE-OVERFLOWING MH MH09003403 WATER BODY AFFECTED-ANACOSTIA RIVER

CLOSEST STREET ADDRESS: 4616 BALTIMORE AVE 20781

COUNTY/PAGE/GRID: P 5409 K09 TOWN/CITY: BLADENSBURG

CAUSE: GREASE AND WIPES EST OVERFLOW VOLUME: 50 GAL

UPON ARRIVAL, THE CREW FOUND MANHOLE 403M OVERFLOWING 1GPM INTO A STORM DRAIN THAT OUTFALLS INTO LOWER ANACOSTIA. THE CREW JETTED FROM MANHOLE 403M TO CONNECTION 344T, A TOTAL OF 193', AND RELIEVED GREASE AND WIPES AT 25', TO END THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:

DISCOLORATION

NOTICEABLE ODOR

PUBLIC ACCESS

PUBLIC USE OBSERVED

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:

THIS MAIN CANNOT BE CCTV INSPECTED DUE TO THE DESIGN AND LOCATION OF THE MAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:

FLUSHED BACK INTO MANHOLE

THE CREW FLUSHED VISIBLE SOLIDS BACK INTO MANHOLE AND WASHED DOWN THE AREA WITH DECHLORINATED WATER.

NOTIFICATIONS MADE:

MD DEPARTMENT OF ENVIRONMENT

PG COUNTY HEALTH DEPT

PG COUNTY MUNICIPALITIES

SIGNS POSTED: 2 POST DATE: 03/21/2025