



# WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3449702-118-2025

MDE OFFICIAL CONTACTED: EVELYN STAVROU

DATA CALLED IN BY: KRISTIN LOELLEN BROWN DATE: 03/31/2025 AT 02:35PM

WORK ORDER(S): 3449702 3449677

EST DATE AND TIME SSO BEGAN: 03/31/2025 12:44PM DURATION: 2.52 HRS  
DATE AND TIME SSO ENDED: 03/31/2025 03:15PM

SOURCE-OVERFLOWING MH MH03037241 WATER BODY AFFECTED-BEAVERDAM BRANCH

CLOSEST STREET ADDRESS: 7122 MEADOW GREEN TER 20785  
COUNTY/PAGE/GRID: P 5530 J06 TOWN/CITY: LANDOVER

CAUSE: ROOTS EST OVERFLOW VOLUME: 25 GAL  
UPON ARRIVAL, THE CREW FOUND EVIDENCE THAT MANHOLE 241M OVERFLOWED A  
TOTAL OF 25 GALLONS. THE CREW JETTED FROM MANHOLE 240M TO MANHOLE  
241M A TOTAL OF 95', AND RELIEVED ROOTS AT 91', TO END THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:  
DRY WEATHER DISCOLORATION  
PUBLIC ACCESS

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:  
THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE  
ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED  
TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE  
THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:  
LIME

THE CREW SPREAD LIME IN THE GRASSY AREA NEAR THE MANHOLE.

NOTIFICATIONS MADE:  
MD DEPARTMENT OF ENVIRONMENT PG COUNTY HEALTH DEPT  
PG COUNTY MUNICIPALITIES

ORIGINALLY REPORTED AS 7104 MEADOW GREEN TERRACE.