



WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3452577-118-2025

MOE OFFICIAL CONTACTED: EVELYN STAVROU

DATA CALLED IN BY: BRANDON T MCCREA

DATE: 04/08/2025 AT 09:12AM

WORK ORDER(S): 3452577 3452571

EST DATE AND TIME SSO BEGAN: 04/08/2025 08:33AM DURATION: 1.95 HRS

DATE AND TIME SSO ENDED: 04/08/2025 10:30AM

SOURCE-OVERFLOWING MH MH15033040 WATER BODY AFFECTED-SENECA CREEK

CLOSEST STREET ADDRESS: 2 DELLCASTLE CT 20886

COUNTY/PAGE/GRID: M 5047 G01 TOWN/CITY: GAITHERSBURG

CAUSE: GREASE EST OVERFLOW VOLUME: 59 GAL

UPON ARRIVAL, THE CREW FOUND MANHOLE 040U OVERFLOWING AT 0.5 GPM. THE CREW JETTED FROM MANHOLE 039M TO 040U A TOTAL OF 101', AND RELIEVED GREASE AT 6', TO END THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:

DRY WEATHER DISCOLORATION
NOTICEABLE ODOR

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:

THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:

FLUSHED BACK INTO MANHOLE

THE JET CREW WASHED DOWN THE PAVEMENT WITH DECHLORINATED WATER.

NOTIFICATIONS MADE:

MD DEPARTMENT OF ENVIRONMENT DEF-MONTGOMERY COUNTY
MONTGOMERY CO MUNICIPALITIES

SIGNS POSTED: 1 POST DATE: 04/08/2025