



WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3456051-118-2025

MDE OFFICIAL CONTACTED: CHRISTIE WAGNER

DATA CALLED IN BY: MARVIN BAILEY

DATE: 04/10/2025 AT 02:15PM

WORK ORDER(S): 3456051 3455994

EST DATE AND TIME SSO BEGAN: 04/10/2025 10:38AM DURATION: 1.87 HRS

DATE AND TIME SSO ENDED: 04/10/2025 12:30PM

SOURCE-OVERFLOWING MH MH11038104 WATER BODY AFFECTED-BROAD CREEK

CLOSEST STREET ADDRESS: 5600 EDGEWOOD DR 20748

COUNTY/PAGE/GRID: P 5650 D10 TOWN/CITY: TEMPLE HILLS

CAUSE: DAMAGED BY OTHERS EST OVERFLOW VOLUME: 224 GAL

UPON ARRIVAL, THE CREW FOUND MANHOLE 104U COVER PUSHED OFF OF THE FRAME AND OVERFLOWING APPROXIMATELY 2GPM, ONTO THE GRASSY AREA AROUND THE MANHOLE, AND INTO AN UNKNOWN CREEK, IN THE BROAD CREEK BASIN. THE CREW JETTED FROM MANHOLE 103M TO MANHOLE 104U, A TOTAL OF 188', AND RELIEVED HEAVY GRAVEL, TO END THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:

DRY WEATHER

DISCOLORATION

NOTICEABLE ODOR

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:

THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:

LIME

THE CREW SPREAD LIME IN THE GRASSY AREA AROUND THE MANHOLE.

NOTIFICATIONS MADE:

MD DEPARTMENT OF ENVIRONMENT

PG COUNTY HEALTH DEPT

PG COUNTY MUNICIPALITIES

SIGNS POSTED: 2 POST DATE: 04/10/2025