



WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3457144-118-2025

MOE OFFICIAL CONTACTED: KENDRA

DATA CALLED IN BY: PATRICIA A HILL DATE: 04/17/2025 AT 05:30PM

WORK ORDER(S): 3457144 3457131

EST DATE AND TIME SSO BEGAN: 04/17/2025 03:36PM DURATION: 3.40 HRS
DATE AND TIME SSO ENDED: 04/17/2025 07:00PM

SOURCE-OVERFLOWING MH MH03016008 WATER BODY AFFECTED-BEAVERDAM BRANCH

CLOSEST STREET ADDRESS: 4301 GARDEN CITY DR 20785
COUNTY/PAGE/GRID: P 5411 B09 TOWN/CITY: LANDOVER

CAUSE: WIPES EST OVERFLOW VOLUME: 408 GAL
UPON ARRIVAL, THE CREW FOUND MANHOLE 008M OVERFLOWING AT 2GPM, INTO A
NEARBY STORM DRAIN THAT OUTFALLS INTO BEAVERDAM BRANCH. THE CREW
RELIEVED HEAVY WIPES AND SANITARY NAPKINS FROM MANHOLE 007M, TO END
THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:
DRY WEATHER NOTICEABLE ODOR
PUBLIC ACCESS

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:
THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE
ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED
TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE
THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:
FLUSHED BACK INTO MANHOLE

THE CREW WASHED DOWN THE AREA AROUND THE MAHHOLE WITH DECHLORINATED
WATER.

NOTIFICATIONS MADE:
MD DEPARTMENT OF ENVIRONMENT PG COUNTY HEALTH DEPT
PG COUNTY MUNICIPALITIES

SIGNS POSTED: 3 POST DATE: 04/17/2025