



WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3470049-118-2025

MDE OFFICIAL CONTACTED: CHRISTIE WAGNER

DATA CALLED IN BY: 4581

DATE: 05/29/2025 AT 12:30PM

WORK ORDER(S): 3470049 3470043

EST DATE AND TIME SSO BEGAN: 05/29/2025 10:45AM DURATION: 0.75 HRS
DATE AND TIME SSO ENDED: 05/29/2025 11:30AM

SOURCE-OVERFLOWING MH MH12015134 WATER BODY AFFECTED-LITTLE FALLS

CLOSEST STREET ADDRESS: 5703 WARWICK PL 20815
COUNTY/PAGE/GRID: M 5407 F06 TOWN/CITY: CHEVY CHASE

CAUSE: GREASE AND WIPES EST OVERFLOW VOLUME: 135 GAL
UPON ARRIVAL, THE CREW FOUND MANHOLE 134M OVERFLOWING 3 GPM ONTO THE
GRASSY AREA AROUND THE MANHOLE. THE CREW JETTED FROM MANHOLE 135U TO
025U, A TOTAL OF 423', AND HIT AND RELIEVED GREASE AND WIPES AT
423', TO END THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:
WET WEATHER

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:
THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE
ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED
TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE
THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:
RAKED AREA VISIBLE SOLIDS REMOVED

THE CREW REMOVED ALL VISIBLE SOLIDS. LIME WAS NOT APPLIED DUE TO
RAIN.

NOTIFICATIONS MADE:
MD DEPARTMENT OF ENVIRONMENT DEP-MONTGOMERY COUNTY
MONTGOMERY CO MUNICIPALITIES

SIGNS POSTED: 11 POST DATE: 05/29/2025