



# WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3470123-118-2025

MDE OFFICIAL CONTACTED: EVELYN STAVROU

DATA CALLED IN BY: MARK A ALEXANDER

DATE: 05/30/2025 AT 11:33AM

WORK ORDER(S): 3470123 3470117

EST DATE AND TIME SSO BEGAN: 05/29/2025 08:55PM DURATION: 4.08 HRS

DATE AND TIME SSO ENDED: 05/30/2025 01:00AM

SOURCE-OVERFLOWING MH MH08004065 WATER BODY AFFECTED-NORTHEAST BRANCH

CLOSEST STREET ADDRESS: 6806 GREENVALE PKWY 20737

COUNTY/PAGE/GRID: P 5410 F09 TOWN/CITY: HYATTSVILLE

CAUSE: WIPES EST OVERFLOW VOLUME: 3 GAL

UPON ARRIVAL, THE CREW FOUND THAT AN UNKNOWN MANHOLE HAD OVERFLOWED APPROXIMATELY 3 GALLONS ONTO THE GRASSY AREA. THE CREW JETTED FROM MANHOLE 014U TO THE UNKNOWN MANHOLE, A TOTAL OF 97', AND HIT AND RELIEVED WIPES AT 49', TO END THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:

NOTICEABLE ODOR

PUBLIC ACCESS

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:

THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:

LIME

THE CREW SPREAD LIME IN THE GRASSY AREA AROUND THE MANHOLE.

NOTIFICATIONS MADE:

PG COUNTY MUNICIPALITIES

PG COUNTY HEALTH DEPT

MD DEPARTMENT OF ENVIRONMENT

SIGNS POSTED: 2 POST DATE: 05/30/2025