



WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3474712-118-2025

MDE OFFICIAL CONTACTED: OLUMIDE

DATA CALLED IN BY: PATRICIA A HILL

DATE: 06/07/2025 AT 07:48PM

WORK ORDER(S): 3474712 3474691

EST DATE AND TIME SSO BEGAN: 06/06/2025 03:57PM DURATION: 2.30 HRS

DATE AND TIME SSO ENDED: 06/06/2025 06:15PM

SOURCE-OVERFLOWING MH MH06032075 WATER BODY AFFECTED-SLIGO CREEK

CLOSEST STREET ADDRESS: 8712 PINEY BRANCH RD 20901

COUNTY/PAGE/GRID: M 5409 A01 TOWN/CITY: SILVER SPRING

CAUSE: DEBRIS EST OVERFLOW VOLUME: 1,380 GAL

UPON ARRIVAL, THE CREW FOUND MANHOLE 075M OVERFLOWING 10 GPM, ONTO THE PAVEMENT, AND INTO A NEAR BY STORM DRAIN THAT ENTERS SLIGO CREEK BASIN. THE CREW JETTED FROM MANHOLE 084U TO 075M, A TOTAL OF 95', AND HIT AND RELIEVED DEBRIS AT 95', TO END THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:

DRY WEATHER DISCOLORATION
NOTICEABLE ODOR PUBLIC ACCESS

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:

THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:

FLUSHED BACK INTO MANHOLE

NOTIFICATIONS MADE:

MD DEPARTMENT OF ENVIRONMENT MONTGOMERY CO MUNICIPALITIES
DEP-MONTGOMERY COUNTY

THE EVENT WAS ORIGINALLY REPORTED AS 8728 PINEY BRANCH ROAD.

SIGNS POSTED: 7 POST DATE: 06/06/2025