



WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3481755-109-2025

MOE OFFICIAL CONTACTED: EVELYN STAVROU

DATA CALLED IN BY: BRANDON T MCCREA

DATE: 07/01/2025 AT 03:00PM

WORK ORDER(S): 3481755 3481669

EST DATE AND TIME SSO BEGAN: 07/01/2025 09:05AM DURATION: 17.12 HRS
DATE AND TIME SSO ENDED: 07/02/2025 02:12AM

SOURCE-REPAIR SEWER MAIN SS05039061 WATER BODY AFFECTED-ROCK CREEK

CLOSEST STREET ADDRESS: 10030 KENSINGTON PKWY 20895
COUNTY/PAGE/GRID: M 5285 J07 TOWN/CITY: KENSINGTON

CAUSE: UNKNOWN EST OVERFLOW VOLUME: 3,082 GAL
UPON ARRIVAL, THE CREW FOUND A BROKEN SEWER PIPE LEAKING INTO AN
UNKNOWN CREEK THAT OUTFALLS INTO ROCK CREEK BASIN, THE CREW JETTED
FROM MANHOLE 061U TO 060M, A TOTAL OF 30', AND FOUND A BROKEN PIPE
THEY WERE UNABLE TO PASS. THE CONTRACTORS THEN SET UP BYPASS, TO END
THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:
WET WEATHER PUBLIC ACCESS
VISIBLE SOLIDS, IN STREAM

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:
THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE
ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED
TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE
THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:

NOTIFICATIONS MADE:
MD DEPARTMENT OF ENVIRONMENT DEP-MONTGOMERY COUNTY
MONTGOMERY CO MUNICIPALITIES

THE EVENT WAS ORIGINALLY REPORTED AS 10011 KENSINGTON PARKWAY.

SIGNS POSTED: 4 POST DATE: 07/02/2025