



WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3491285-109-2025

MDE OFFICIAL CONTACTED: OLUMIDE OGUNLEYI

DATA CALLED IN BY: SHEMIEKA MONIQUE HARDING DATE: 08/06/2025 AT 05:34PM

WORK ORDER(S): 3491285 3491268

EST DATE AND TIME SSO BEGAN: 08/06/2025 03:32PM DURATION: 7.47 HRS
DATE AND TIME SSO ENDED: 08/06/2025 11:00PM

SOURCE-REPAIR SEWER MAIN SS05101012 WATER BODY AFFECTED-ROCK CREEK

CLOSEST STREET ADDRESS: 12101-513 VILLAGE SQUARE TER 20852
COUNTY/PAGE/GRID: M 5285 C01 TOWN/CITY: ROCKVILLE

CAUSE: UNKNOWN EST OVERFLOW VOLUME: 4,482 GAL
UPON ARRIVAL, THE CREW FOUND SEWAGE SURFACING AND LEAKING
APPROXIMATELY 10 GPM INTO A NEARBY CREEK, IN THE ROCK CREEK BASIN. A
WSSC CONTRACTOR SET-UP A BYPASS SYSTEM FROM MANHOLE 012M TO 011M, TO
END THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:
DRY WEATHER NOTICEABLE ODOR
PUBLIC ACCESS VISIBLE SOLIDS, STREAM BANK

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:
THE CONTRACTORS ARE SCHEDULED TO REPAIR THE PIPE. A FOLLOW-UP
INVESTIGATION WILL BE CONDUCTED TO DETERMINE WHAT MEASURES SHOULD BE
TAKEN TO REDUCE OR ELIMINATE THE CHANCE OF THIS LINE OVERFLOWING
AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:
FLUSHED BACK INTO MANHOLE LIME

THE CREW SPREAD LIME AROUND THE AFFECTED AREA.

NOTIFICATIONS MADE:
MD DEPARTMENT OF ENVIRONMENT MONTGOMERY CO MUNICIPALITIES
DEP-MONTGOMERY COUNTY

THE EVENT WAS ORIGINALLY REPORTED AS 12300 VILLAGE SQUARE TERRANCE.

SIGNS POSTED: 24 POST DATE: 08/06/2025