



# WASHINGTON SUBURBAN SANITARY COMMISSION

## SANITARY SEWER OVERFLOW WRITTEN REPORT

3493840-118-2025

MDE OFFICIAL CONTACTED: KENDRA DUKES

DATA CALLED IN BY: KRISTIN LOELLEN BROWN      DATE: 08/23/2025 AT  
05:31PM

WORK ORDER(S): 3493840      3493831

EST DATE AND TIME SSO BEGAN: 08/23/2025 12:15PM      DURATION: 2.08 HRS  
DATE AND TIME SSO ENDED: 08/23/2025 02:20PM

SOURCE-OVERFLOWING MH      MH11034068      WATER BODY AFFECTED-BROAD CREEK

CLOSEST STREET ADDRESS: 4708      BRINKLEY RD      20748  
COUNTY/PAGE/GRID: P 5766 B02      TOWN/CITY: TEMPLE HILLS

CAUSE: ROOTS      EST OVERFLOW VOLUME: 125GAL

UPON ARRIVAL, MANHOLE 068M WAS OVERFLOWING 1GPM, ONTO THE GRASSY AREA AROUND THE MANHOLE. THE CREW JETTED FROM MH067M TO MH068M, A TOTAL OF 166FT, AND HIT AND RELIEVED A MEDIUM ROOT OBSTRUCTION AT 156FT, TO END THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:  
NOTICEABLE ODOR      PUBLIC ACCESS  
DRY WEATHER

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:  
THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:  
LIME

THE CREW SPREAD LIME IN THE GRASSY AREA AROUND THE MANHOLE.

NOTIFICATIONS MADE:  
PG COUNTY MUNICIPALITIES      MD DEPARTMENT OF ENVIRONMENT  
PG COUNTY HEALTH DEPT

SIGNS POSTED: 2      POST DATE: 08/23/2025