



WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3495040-118-2025

MDE OFFICIAL CONTACTED: EVELYN STRAVOU

DATA CALLED IN BY: MARVIN BAILEY

DATE: 08/27/2025 AT 01:27PM

WORK ORDER(S): 3495040 3494991

EST DATE AND TIME SSO BEGAN: 08/27/2025 08:46AM DURATION: 3.90 HRS

DATE AND TIME SSO ENDED: 08/27/2025 12:40PM

SOURCE-OVERFLOWING MH MH14123002 WATER BODY AFFECTED-WESTERN BRANCH

CLOSEST STREET ADDRESS: 11518 BENNINGTON DR 20774

COUNTY/PAGE/GRID: P 5532 B09 TOWN/CITY: UPPER MARLBORO

CAUSE: DEBRIS EST OVERFLOW VOLUME: 702 GAL

UPON ARRIVAL, THE CREW FOUND MANHOLE 002M OVERFLOWING APPROXIMATELY 3 GPM, ONTO THE GRASSY AREA AROUND THE MANHOLE, AND INTO A NEARBY CREEK IN THE WESTERN BRANCH BASIN. THE CREW JETTED FROM MANHOLE 117U THROUGH MANHOLE 002M, AND RELIEVED A RAGS OBSTRUCTION AT 376', TO END THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:

DRY WEATHER

NOTICEABLE ODOR

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:

THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:

LIME

THE CREW SPREAD LIME AROUND THE MANHOLE.

NOTIFICATIONS MADE:

PG COUNTY MUNICIPALITIES

PG COUNTY HEALTH DEPT

MD DEPARTMENT OF ENVIRONMENT

SIGNS POSTED: 2 POST DATE: 08/27/2025