



# WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3498103-118-2025

MDE OFFICIAL CONTACTED: MR OLUMIDE

DATA CALLED IN BY: DIARRA K MACKALL

DATE: 08/31/2025 AT 05:58PM

WORK ORDER(S): 3498103 3498098

EST DATE AND TIME SSO BEGAN: 08/31/2025 12:46PM DURATION: 2.23 HRS

DATE AND TIME SSO ENDED: 08/31/2025 03:00PM

SOURCE-OVERFLOWING MH MH18996019 WATER BODY AFFECTED-OXON RUN

CLOSEST STREET ADDRESS: 736 MAURY AVE 20745

COUNTY/PAGE/GRID: P 5649 A09 TOWN/CITY: OXON HILL

CAUSE: DAMAGED BY OTHERS EST OVERFLOW VOLUME: 268 GAL

UPON ARRIVAL, THE CREW FOUND MANHOLE 019M OVERFLOWING APPROXIMATELY 2 GPM, INTO A NEARBY STORM DRAIN IN THE OXON RUN BASIN. THE CREW JETTED FROM MANHOLE 018U TO 019M AND RELIEVED A BLOCKAGE CONSISTING OF HEAVY ASPHALT DEPOSITS WITHIN MANHOLE 019M, TO END THE EVENT. MULTIPLE RESIDENTS REPORTED THAT A CONTRACTOR HAD BEEN MILLING THE ROAD NEARBY, AND ASPHALT MATERIAL ENTERED THE MANHOLE.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:

DRY WEATHER	DISCOLORATION
NOTICEABLE ODOR	PUBLIC ACCESS

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:

THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:

FLUSHED BACK INTO MANHOLE

NOTIFICATIONS MADE:

PG COUNTY HEALTH DEPT	MD DEPARTMENT OF ENVIRONMENT
PG COUNTY MUNICIPALITIES	

SIGNS POSTED: 1 POST DATE: 08/31/2025