



# WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3500063-118-2025

MDE OFFICIAL CONTACTED: OLUMIDE OGUNLEYE

DATA CALLED IN BY: SHEMIEKA MONIQUE HARDING      DATE: 09/02/2025 AT 07:39PM

WORK ORDER(S): 3500063      3500032

EST DATE AND TIME SSO BEGAN: 09/02/2025 04:16PM      DURATION: 6.07 HRS  
DATE AND TIME SSO ENDED: 09/02/2025 10:20PM

SOURCE-OVERFLOWING MH      MH07067061      WATER BODY AFFECTED-CABIN JOHN

CLOSEST STREET ADDRESS: 9101      CLEWERWALL DR      20817  
COUNTY/PAGE/GRID: M 5284 C10      TOWN/CITY: BETHESDA

CAUSE: GREASE      EST OVERFLOW VOLUME: 364 GAL  
UPON ARRIVAL, THE CREW FOUND MANHOLE 061M OVERFLOWING AT 1 GPM, INTO A  
NEARBY CREEK THAT FLOWS INTO THE CABIN JOHN BASIN. THE CREW JETTED  
FROM MANHOLE 026M TO 061M, A TOTAL OF 325', AND HIT AND RELIEVED A  
HEAVY GREASE BLOCKAGE AT 325', TO END THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:  
DISCOLORATION      DRY WEATHER  
NOTICEABLE ODOR      PUBLIC ACCESS

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:  
THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE  
ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED  
TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE  
THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:  
LIME      VISIBLE SOLIDS REMOVED

THE CREW SPREAD LIME AROUND THE AFFECTED AREA.

NOTIFICATIONS MADE:  
MD DEPARTMENT OF ENVIRONMENT      MONTGOMERY CO MUNICIPALITIES  
DEP-MONTGOMERY COUNTY

SIGNS POSTED: 8      POST DATE: 09/03/2025