



WASHINGTON SUBURBAN SANITARY COMMISSION

SANITARY SEWER OVERFLOW WRITTEN REPORT

3500068-118-2025

MDE OFFICIAL CONTACTED: OLUMIDE OGUNLEYE

DATA CALLED IN BY: SHEMIEKA MONIQUE HARDING DATE: 09/02/2025 AT 08:33PM

WORK ORDER(S): 3500068 3500060

EST DATE AND TIME SSO BEGAN: 09/02/2025 07:05PM DURATION: 2.92 HRS
DATE AND TIME SSO ENDED: 09/02/2025 10:00PM

SOURCE-OVERFLOWING MH MH08069046 WATER BODY AFFECTED-NORTHEAST BRANCH

CLOSEST STREET ADDRESS: 7501 MUIRKIRK RD 20705
COUNTY/PAGE/GRID: P 5288 K02 TOWN/CITY: BELTSVILLE

CAUSE: ROOTS & GREASE EST OVERFLOW VOLUME: 526 GAL
UPON ARRIVAL, THE CREW FOUND MANHOLE 046M OVERFLOWING AT 3 GPM INTO A
NEARBY TRIBUTARY THAT OUTFALLS INTO NORTHEAST BRANCH. THE CREW JETTED
FROM MANHOLE 043M THROUGH MANHOLES 044M AND 045M, A TOTAL OF 975', AND
RELIEVED ROOTS AND GREASE AT 850', TO END THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:
DRY WEATHER NOTICEABLE ODOR
PUBLIC ACCESS

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:
THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE
ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED
TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE
THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:
LIME

THE CREW SPREAD LIME AREA THE AFFECTED AREA.

NOTIFICATIONS MADE:
PG COUNTY HEALTH DEPT MD DEPARTMENT OF ENVIRONMENT
PG COUNTY MUNICIPALITIES

SIGNS POSTED: 5 POST DATE: 09/03/2025